

# Wisconsin Recreational Facilities FACT SHEET

## Water Quality Standards

Minimum Disinfectant Residuals- TABLE ATCP 76.14			
Pool Type	Free Chlorine	Chlorine Residual with Stabilizer (Cyanuric Acid)	Total Bromine
Swimming and Activity Pool	1.0 ppm	2.0 ppm	3.0 ppm
Wading Pool	2.0 ppm	4.0 ppm	4.0 ppm
Whirlpool, Exercise, Therapy Pools	3.0 ppm	6.0 ppm	4.0 ppm
Water Attractions Other Than Those Specified	1.0 ppm	2.0 ppm	3.0 ppm
Plunge Pool and Wave Pool	2.0 ppm	4.0 ppm	3.0 ppm
*Electronic Monitoring Device (ORP system)	*1.0 ppm	*1.0 ppm	3.0 ppm
Interactive Play Attraction (Splash Pads)	2.0 ppm	4.0 ppm	3.0 ppm
Waterslides and Pool Slide	2.0 ppm	4.0 ppm	3.0 ppm

\*Except for whirlpools, therapy pools and exercise pools; when a pool is equipped with an approved and properly functioning electronic monitoring device to control the chlorine residual and pH level, the free available chlorine residual may be a minimum of 1.0 ppm.

Water Chemistry Standards- ATCP 76.14			
Parameters	Minimum	Maximum	Closure- ATCP 76.30
Chlorine disinfectant	See table above	10 ppm	Below minimum levels or above 10 ppm
Bromine disinfectant	See table above	10 ppm	Below minimum levels or above 10 ppm
pH	7.2	7.8	Below 6.8 or 8.0 or above
Cyanuric Acid (Stabilizer)	-	30 ppm	Above 300 ppm
Total Alkalinity	*60 ppm	*180 ppm	n/a
Combined Chlorine	A combined chlorine management plan must be in use at the facility. The recommended action level for breakpoint chlorination is 0.4 ppm combined chlorine.		

\*Total Alkalinity shall be maintained between 60- 180 ppm unless it can be shown by the pool operator that another level of total alkalinity produces chemically balanced water based on Saturation Index calculation.



Wisconsin Department of Agriculture,  
Trade and Consumer Protection  
Division of Food and Recreational Safety  
2811 Agriculture Drive, PO Box 8911  
Madison, WI 53708    datcp.wi.gov

Water Testing Frequency- ATCP 76.18		
Parameters	Pools and Water Attractions	Whirlpools, Therapy & Exercise Pools
pH & Disinfectant: Chlorine or Bromine	**2x/day	***4x/day
*Electronic Monitoring Device (ORP system)	*1x/day	*1x/day
Combined Chlorine	2x/week	1x/day
Total Alkalinity	1x/week	1x/week
Cyanuric Acid (Stabilizer)	1x/week	1x/week

\* ORP devices must be continually monitored and kept between 650 mV – 900 mV.

\*\* Testing shall be performed before opening and during peak patron load.

\*\*\* Testing shall be performed before opening and three more times during use.

Water Temperature Standards- ATCP 76.19		
Pool Type	Minimum	Maximum
Indoor Pools	70° F	90°F
Outdoor Pools	65° F	-
Whirlpools	Greater than 90° F	104°F
Cold Soak Pools	Temperature (°F) must be posted in 4” letters	-



Wisconsin Department of Agriculture,  
Trade and Consumer Protection  
Division of Food and Recreational Safety  
2811 Agriculture Drive, PO Box 8911  
Madison, WI 53708      [datcp.wi.gov](http://datcp.wi.gov)